


**LEGENDE :**

— CABLAGE USINE      □ BORNE DE RACCORDEMENT

— CABLAGE INSTALLATEUR      - - - - - SHUNT PUMP DOWN



**BORNIER X DE RACCORDEMENT**

ALIM. 230VCA	←	PHASE 230V	Noir	1	Shunt 1&2 = Avec Pump Down	
PRESSOSTAT	←	CONTACT	Noir	2		
ELECTROVANNE	←	PHASE 230V	Noir	3		Shunt 2&3 = Sans Pump Down
RESISTANCES CARTER	←	PHASE 230V	Noir	4		
PRESSOSTAT	←	CONTACT	Noir	5		
VENTIL. CONDENSEUR	←	PHASE 230V	Noir	6		
ALARME	←	PHASE 230V	Noir	7		
VENTILATION EVAP.	←	PHASE 230V	Noir	8		
ALIM. 230VCA	←	NEUTRE 230V	Bleu	N	ALARME	
ELECTROVANNE	←	NEUTRE 230V	Bleu	N		VENTILATION EVAP.
RESISTANCES CARTER	←	NEUTRE 230V	Bleu	N		
VENTIL. CONDENSEUR	←	NEUTRE 230V	Bleu	N		

**ESF**  
94190 VILLENEUVE  
SAINT GEORGES

DESSINE :	TC	C	13/04/2018	MISE A JOUR	TC
VERIFIE :	TC	B	29/04/2009	MISE A JOUR	TC
DATE DE CREATION :		A	28/03/2006	EDITION ORIGINAL	TC
INDICE		DATE		MODIFICATION	VISA

Dossier n° :

**PT-S (Ventil. Evap. Mono)**  
COFFRET POSITIF TRI (avec sectionneur)  
PUISSANCE + COMMANDE + RACCORDEMENT